

L. Roberto Lomas P.E.

1432 Woodford Rd.

Lewisville, NC 27023

336-945-9695

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511862

Manufacturer: VuSafe Industries, LLC
350 Kidds Hill Road
Hyannis, MA 02601

Product Line: Storm Shutter Type A

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Community Affairs for Statewide Acceptance per Rule 9N-3. The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01260, titled Storm Shutter Type A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ETC-07-1089-19072.2 signed and sealed by Joseph Labora Doldan P.E.
ETC Laboratories, Rochester, New York
ASTM E330-02 Design Pressure: ± 50 psf
ASTM E1886-05 and ASTM E1996-05
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
ASTM E1886/ E1996 Cyclic Load Test, ± 50.0 psf design pressure
3. Anchor calculations, report number 511862-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 50 psf
- Maximum Panel Height: 108"
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.

Installation: Units must be installed in accordance with approval document, 08-01260.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

